



Certificate of Compliance

Certificate: 80063716

Master Contract: 301563

Project: 80063716

Date Issued: 2021-03-22

Issued To: Guangdong Weipu Electrical Appliance Co., Ltd.
No.3 Puling Road,
Dayan Industrial Estate,
Huangpu Town,
Zhongshan City, Guangdong, 528429
China

Attention: Cheng Jinshun

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: *Dino Du*
Dino Du



PRODUCTS

CLASS 6233 01 - RECEPTACLES Attachment Plug Type and Plugs

CLASS 6233 81 - RECEPTACLES Attachment Plug Type and Plugs - Certified to US Standards

Special use connectors, WA22 series, consisted of male and female connectors, 3-Pole 4-Wire:

Part	Male connector		Female Connector		Rating
	Cat. No.	Configuration	Cat. No.	Configuration	
A	WA22J4TE2	Special use	WA22K4Z2	Special use	400Vac, 16 A max; or 250Vac, 16A max
B	WA22J4Z2		WA22K4ZE2		
C	WA22J4TK2		WA22K4TK2		
D	WA22J4TL2		WA22K4TL2		

Note:

1. These devices are intended for shipment to original equipment manufacturers as components of certified electrical equipment where the suitability of the combination is to be determined in the end use.
2. These connectors are not for interrupting current.



Certificate: 80063716
Project: 80063716

Master Contract: 301563
Date Issued: 2021-03-22

APPLICABLE REQUIREMENTS

- CSA C22.2 No. 182.3-16 - Special Use Attachment Plugs, Receptacles and Connectors
- UL 1977, 3rd Ed - Component Connectors for Use in Data, Signal, Control and Power Applications



Supplement to Certificate of Compliance

Certificate: 80063716

Master Contract: 301563

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80063716	2021-03-22	Supersedes report 1821882 to increase maximum rated current of WA22 Series to 16A, remove Cat Nos WA22J4T and WA22K4Z.